Illinois WDI inspection field sheet

Notes for the NPMA-33

Company and inspector	
Inspection company Prairie Shield Pest Control, 1840 W. Jefferson St., Joliet, IL 60435	
Company license number 4312	**Inspection date** November 18, 2026
Inspector and IDPH number Marcus Delgado; cert. 060-21876	

Property and order	
Property address 1127 Sycamore Ln, Naperville, IL 60540	
Ordered by Kelly Brandt, buyer’s agent	**Closing date** December 4, 2026
Structures inspected House with attached garage and attached rear deck	

Findings by area

Area	Evidence or damage	Exact location
Basement	Dry shelter tubes, no live termites	East wall, 6 ft north of window well
Basement	Probed sill plate, sound	East wall above tubes
Garage	No visible evidence	All accessible walls
Rear deck	No visible evidence	Posts and ledger board

Obstructions
Area and obstruction key Basement: 1, 3, 7 (stored boxes, paneling, drop ceiling)
Areas not inspected Crawl space under family room; access panel screwed shut

Illinois WDI inspection field sheet (continued)

Notes for the NPMA-33

Prior treatment	
Papers shown None at time of visit	**Service agreement ends** No agreement found

Result	
Box A or B B, item 2 (old shelter tubes)	**Treatment recommended** Yes, subterranean termites; no proof of past treatment
Attachments listed Photo page (4 photos); basement sketch	