Illinois private sewage evaluation worksheet

77 Ill. Adm. Code 905.20(q)

Property and evaluator	
Owner Gary and Lynn Hoffmann	**Phone** (815) 555-0148
Site address 9810 Alden Rd, Woodstock, IL 60098	
Evaluator and title Erin Novak, licensed installation contractor	**Date of inspection** October 29, 2026
Rain in last 48 hours None	

Septic tank	
Inlet baffle Good	**Outlet baffle** Good
Water level Good	**Tank capacity** 1,000 gal, 54 in. liquid depth
Sludge inches 12	**Scum inches** 5
Percent of liquid depth 31% (under 33%)	**Last pumped** May 2021

Pump and distribution	
Distribution box No sludge present	
Float and alarm No pump tank	**Pump condition** Not applicable

Seepage field	
Location and length Rear yard, 3 trenches, about 300 linear ft	
Surfacing or saturation None	**Vegetation and trees** Silver maple 12 ft from last trench

Illinois private sewage evaluation worksheet (continued)

77 Ill. Adm. Code 905.20(q)

Records
Permit or install date County permit 2015-0412, installed 2015
Maintenance records seen 2021 pump receipt only

Comments and signature	
Comments No failure signs. Pump within the next year and watch the maple roots.	
Evaluator signature Erin Novak	**Date** October 29, 2026