Indiana onsite sewage inspection worksheet

410 IAC 6-8.3

Property	
Owner Mark and Julie Ostrowski	**Phone** (219) 555-0162
Site address 472 N. 350 W, Valparaiso, IN 46385	
Inspector Ryan Dekker, Porter Septic Service	**Date** October 21, 2026
Recent rain 0.4 in. two days before	

County file	
County permit Porter County 1999-0318	**Install year** 1999
Operating permit None required	**Service company** None on file

Septic tank	
Tank size 1,000 gal, two compartments	**Riser and cover** No riser; lids 14 in. below grade
Sludge inches 16	**Scum inches** 4
Outlet filter None	**Last pumped** 2019, per seller

Soil absorption field
Field type and size Gravity trenches, 4 x 75 ft
Ponding or seepage Soft, wet ground over trench 4

Indiana onsite sewage inspection worksheet (continued)

410 IAC 6-8.3

Failure check		
Sign of failure	**Seen**	**Notes**
Won’t accept sewage	No	Fixtures drained normally
Surface ponding or seepage	Possible	Wet ground over trench 4
Water contamination	Not checked	No well sample taken

Result	
Recommendation Pump the tank. Have a licensed installer evaluate trench 4. Add risers and an outlet filter.	
Inspector signature Ryan Dekker	**Signed date** October 21, 2026