Kentucky existing septic system inspection

902 KAR 10:085

Property	
Property address 2910 Petersburg Road, Hebron, KY 41048	
Owner Gerald and Faye Lindsey	**Requested by** Natalie Brooks, buyer
Inspection date June 3, 2026	**Home occupied** Yes

System records	
Health department file Construction permit and installer affidavit, 2004	**Bedrooms** 3
Tank type Concrete septic tank	**Tank capacity** 1,000 gallons
Lateral line length 300 ft	**System age** 22 years
Water supply City water	**Last pumped** April 2023

Components checked

Component	How checked	Condition
Inlet baffle	Lid opened at grade	Intact
Outlet baffle	Riser opened	Cracked at the tee
Sludge and scum	Measured with sludge judge	About 1/3 of depth
Lateral field	Walked and probed	No wet spots or odor

Kentucky existing septic system inspection (continued)

902 KAR 10:085

Not located or not checked
Items and reasons Distribution box not found, no as-built showing its location

Result	
Summary Tank sound, outlet baffle cracked. No surfacing over the field.	
Next step Replace outlet baffle. Ask the county health department if a permit is needed.	
Inspector Wade Hollins	**Report date** June 4, 2026