Minnesota radon measurement worksheet

Site record and report handoff

Measurement job	
Property address 3672 Keats Avenue North, Lake Elmo, MN 55042	
Client Leah Nelson	**Licensed professional** Avery Holm
License No. RM-3267	**Device ID** CRM 2186

Placement and conditions	
Room, floor, placement Lowest lived-in level, family room interior shelf.	
Start November 6, 2026 at 10:05 a.m.	**Stop** November 8, 2026 at 10:20 a.m.
Closed-building conditions Confirmed with owner	**Changes or interference** None reported

Results and handoff	
Result (pCi/L) 2.3 pCi/L	**Report reference** Report 26-1108-H
Mitigation info observed No mitigation fan or vent piping seen.	
Report sent to Leah Nelson	**Date sent** November 9, 2026