Onsite wastewater system assessment

19 CSR 20-3.070

Site information	
Property address 238 Hidden Acres Road, Camdenton, MO 65020	
Owner name Ronald and Patricia Keim	**Requested by** Ozark Lakes Mortgage, for buyer Erin Caldwell
Job number OSI-2026-0417	**Assessment date** September 9, 2026
Bedrooms listed 3	**Bedrooms found** 3, plus office without closet

Inspector	
Inspector name Tyler Brockman	**DHSS license no.** PI-11829
Company Osage Ridge Onsite Services	**Phone** (573) 555-0149

Assessment type
Inspection or evaluation Inspection
Reason for evaluation Not applicable

Tanks	
Tank type Two-compartment concrete septic tank	**Tank size** 1,250 gallons
Liquid level Normal, at outlet	**Baffles** Inlet tee missing, outlet tee in place

Soil treatment area	
System type Gravity lateral lines, 3 runs	**Hydraulic load** 180 gallons at 8 gpm, no surfacing
Surfacing or seepage None seen during or after the water load	

Onsite wastewater system assessment (continued)

19 CSR 20-3.070

Water supply	
Supply type Private drilled well	**Bacteria result** Total coliform absent

Result and copies	
Defects found Missing inlet tee in first compartment	
Sent to DHSS September 22, 2026, by email	**Copies sent to** Camden County, lender, owner